

UNDERGROUND STORAGE TANK(S)

SITE NAME: Phillips Management

REGULATED ✓

NONREGULATED       

YES

NO

RELEASE CONFIRMED:       

✓

CLEAN-UP INITIATED:       

      

TANK(S) REMOVED: ✓

      

RELEASE UNDER CONTROL:       

      

CLEAN-UP COMPLETED:       

✓

TECHNICIAN: W. B. G.

DATE: 8/5/93

✓ USGS MAP

✓ BASE MAP

✓ ORIENTATION OF UST

18' LENGTH OF UST

64" DIAMETER OF UST

3K VOLUME OF UST

gas MATERIAL STORED

✓ SAMPLE LOCATIONS

12' DEPTH OF SAMPLE

floor SIDE OR FLOOR SAMPLE

4' DEPTH OF TANK BURIAL

backhoe HOW SAMPLE WAS COLLECTED

icc SAMPLES PRESERVED AND TRANSPORTED

by lab TOOLS DECONTAMINATED

✓ TIME/DATE SAMPLE COLLECTED

✓ TIME/DATE LAB RECEIVED

<10 LAB RESULTS

5030 ANALYSIS METHOD

✓ C.O.C.

✓ REFERENCE TO SAMPLING POINT ON MAP

✓ CORRECT # OF SAMPLES

✓ WITHIN 14 DAYS HOLDING TIME FOR SAMPLES

Saturnway TANK DESTINATION

NA DISPOSITION OF SOIL

6-15-93 REMOVAL DATE

✓ COMPLETE GW/UST-2 FORM